

Conduit Inspection

Date: 16/12/2017	Asset owner's job ref.:	Asset Owner:	Operator :	Section number: 20	Pipe Asset Id:
Time of inspection: 08:48:53	Cleaning: Not Cleaned	Standard: WSA 05-2008 2.2	LRP Ins	Conduit Unit Length	Method of Inspection Television Camera

Town: Suburb: Street: Asset Location Main road - urban	Catchment: Asset Owner: Precipitation.: Fine Flow control No measures	US MH: Survey Dir: downstream DS MH: Inspect Lenght : 20.90 m
--	--	--

Purpose of inspection : Routine Inspection	Shape : Circular
Use of Conduit: Sewage	Dia/Height: 150 mm
Type of Conduit: Gravity sewer	Lining:
Lining Method:	Pipe Material: PVC-Plasticised

Remarks :

1:165	Position	Observation	Photo
		<p>Start node, maintenance hole, Nodename:</p> <p><u>0.70</u> S1 Deposits on the wall, grease, Reduction in the cross sectional area , Obstruction: <5% , from 12 to 12 o'clock, Start</p> <p><u>0.70</u> Water level, turbid or discoloured flow, depth 5%</p> <p><u>20.90</u> A Mass of mostly fine Roots, which has developed into an interwoven clump , Obstruction: 21-50% , from 12 to 12 o'clock</p> <p><u>20.90</u> E1 Deposits on the wall, grease, Reduction in the cross sectional area , Obstruction: <5% , from 12 to 12 o'clock, End</p> <p><u>20.90</u> Inspection (survey) abandoned, obstruction , MASS ROOTS</p>	<p>20_4A</p> <p>20_6A</p>

STR no def	STR peak	STR mean	STR total	STR grade	SER no def	SER peak	SER mean	SER total	SER grade
0	0	0	0	1	2	45	6.75	141	4

Inspection Pictures

Location/Street	Town or suburb:	Date : 16/12/2017	Section number: 20	Sewer Ref.:
-----------------	-----------------	-----------------------------	------------------------------	-------------




Photo: 085154_16122017_20.JPG
 20.9m, A Mass of mostly fine Roots, which has developed into an interwoven clump ,
 Obstruction: 21-50% , from 12 to 12 o'clock




Photo: 085540_16122017_20.JPG
 20.9m, Inspection (survey) abandoned, obstruction , MASS ROOTS

Section: 20


Inspection: 1

Location:

Street:

Date: 16/12/2017

Visa:



Pipe shape: C Pipe height: 150.00 Pipe width: 0.00